

CERTIFIED MAIL – RETURN RECEIPT REQUESTED
ARTICLE NO 7005 1160 0003 3097 2352

April 10, 2008

Ms. Anne Roberts, Enforcement Administrator
NPDES Enforcement Section
Arkansas Department of Environment Quality
5301 N. Shore Drive
North Little Rock, AR 72218

RE: Updated Adams Field Treatment Plant, Secondary Diversion Flows
NPDES Permit No. AR 0021806
State Permit No. 65WR1

Dear Ms Roberts:

This updated letter is being sent to reflect a change in the last paragraph of the previous correspondence. We now use Ultra-Violet Light for disinfection and have corrected this for any future correspondence.

Little Rock received 1.92 inches of rainfall between April 3 and 4. This amount of rainfall caused our peak plant flow to exceed the process component's capacity. Peak flow rate during this period reached 90.37 MG. The flow diverted around the secondary system is indicated in the following table.

<u>Flow Date</u>	<u>Influent Flow</u>	<u>Secondary System Flow</u>	<u>Flow Diverted</u>
04/04	61.75 MG	58.33 MG	2.58 MG
04/05	61.35 MG	56.95 MG	3.51 MG

This flow diversion of peak flow around process components was anticipated during this high flow rainfall related event.

This flow diversion did not result in any effluent water quality violations with the total effluent flow continually receiving UV Disinfection. We do not foresee any problems meeting our weekly and monthly permit limitations for April as a result of this flow diversion.

LITTLE ROCK WASTEWATER UTILITY

Perry O. Thornton, Superintendent
Adams Field WWTP
POT: jdr

Cc: Reggie A. Corbitt, P.E. and CEO
Stan Miller, Manager of Operations
Stanley Suel, Director of Environmental Assessment Department
Reader's File