

CERTIFIED MAIL – RETURN RECEIPT REQUESTED  
ARTICLE NO 7007 0710 0005 6224 5576

April 14, 2008

Ms Anne Roberts, Enforcement Administrator  
NPDES Enforcement Section  
Arkansas Department of Environment Quality  
5301 N. Shore Drive  
North Little Rock, AR 72218

RE: Adams Field Treatment Plant, Secondary Diversion Flows  
NPDES Permit No. AR 0021806  
State Permit No. 65WR1

Dear Ms Roberts:

Little Rock received 4.5 inches of rainfall between April 9 and 10. This amount of rainfall caused our peak plant flow to exceed the process component's capacity. Peak flow rate during this period reached 98.03 MG. The flow diverted around the secondary system is indicated in the following table.

<u>Flow Date</u>	<u>Influent Flow</u>	<u>Secondary System Flow</u>	<u>Flow Diverted</u>
04/09	59.63 MG	55.61 MG	3.20 MG
04/10	69.60 MG	45.99 MG	22.76 MG
04/11	62.21 MG	52.89 MG	8.51 MG

This flow diversion of peak flow around process components was anticipated during this high flow rainfall related event.

This flow diversion did not result in any effluent water quality violations with the total effluent flow continually receiving UV Disinfection. We do not foresee any problems meeting our weekly and monthly permit limitations for April as a result of this flow diversion.

LITTLE ROCK WASTEWATER UTILITY

Perry O. Thornton, Superintendent  
Adams Field WWTP  
POT: jdr

Cc: Reggie A. Corbitt, P.E. and CEO  
Stan Miller, Manager of Operations  
Stanley Suel, Director of Environmental Assessment Department  
Reader's File