

CERTIFIED MAIL – RETURN RECEIPT REQUESTED
ARTICLE NO 7008 1140 0000 8580 0323

May 8, 2009

Ms Anne Roberts, Enforcement Assistant
NPDES Enforcement Section
Arkansas Department of Environment Quality
5301 Northshore Drive
North Little Rock, AR 72118-5317

RE: Adams Field Treatment Plant, Secondary Diversion Flows
NPDES Permit No. AR 0021806
State Permit No. 65WR1

Dear Ms. Roberts:

Adams Field Wastewater Treatment Plant received 3.16 inches of rainfall and the collection system received an additional average rainfall of 2.00 inches between May 5 and 6, 2009. These amounts of rainfall caused our peak plant flow to exceed process component's capacity. Peak flow rate during this period reached 93.09 MG. The flow diverted around the secondary system is indicated in the following table.

<u>Flow Date</u>	<u>Influent Flow</u>	<u>Secondary System Flow</u>	<u>Flow Diverted</u>
05/06	71.80 MG	61.21 MG	9.70 MG
05/07	69.45 MG	60.40 MG	9.10 MG

These diversions of peak flow around process components were anticipated during this high flow rainfall related event.

These flow diversions did not result in any effluent water quality violations with the total effluent flow continually receiving UV disinfection. We do not foresee any problems meeting our weekly and monthly permit limitations for May as a result of these flow diversions.

LITTLE ROCK WASTEWATER UTILITY

Perry O. Thornton, Superintendent
Adams Field WWTP

POT: jdr

Cc: Reggie A. Corbitt, P.E. and CEO
Stan Miller, Director of Operations
Stanley Suel, Director of Environmental Assessment Dept.
Reader's File