

CERTIFIED MAIL – RETURN RECEIPT REQUESTED  
ARTICLE NO 7007 1160 0003 3097 2109

September 8, 2008

Ms Anne Roberts, Enforcement Assistant  
NPDES Enforcement Section  
Arkansas Department of Environment Quality  
5301 N. Shore Drive  
Little Rock, AR 72218

RE: Adams Field Treatment Plant, Secondary Diversion Flows  
NPDES Permit No. AR 0021806  
State Permit No. 65WR1

Dear Ms. Roberts:

Little Rock received 7.35 inches of rainfall between September 2 and 4, 2008. This amount of rainfall caused our peak plant flow to exceed process component's capacity. During this rainfall event, one (1) final clarifier was out-of-service for mechanical repairs. Peak flow rate during this period reached 80.97 MG. The flow diverted around the secondary system is indicated in the following table.

<u>Flow Date</u>	<u>Influent Flow</u>	<u>Secondary System Flow</u>	<u>Flow Diverted</u>
09/03	73.90 MG	54.11 MG	19.52 MG
09/04	73.63 MG	40.39 MG	32.95 MG
09/05	62.91 MG	39.56 MG	22.98 MG

These diversions of peak flow around process components were anticipated during this high flow rainfall related event.

These flow diversions did not result in any effluent water quality violations with the total effluent flow continually receiving UV disinfection. We do not foresee any problems meeting our weekly and monthly permit limitations for September as a result of these flow diversions.

LITTLE ROCK WASTEWATER UTILITY

Perry O. Thornton, Superintendent  
Adams Field WWTP

POT: jdr

Cc: Reggie A. Corbitt, P.E. and CEO  
Stan Miller, Director of Operations  
Stanley Suel, Director of Environmental Assessment Dept.  
Reader's File